# **2000 Gallon Septic Tank (Holding or Pump)**43" LIQUID LEVEL

43" LIQUID LEVEL 48" INLET 46" OUTLET 2,051 GALLONS ACTUAL 84" MAXIMUM BURY 20,000# EMPTY WEIGHT

### **DESIGN NOTES:**

QUALITY CONTROL PROGRAM IN PLACE
W/C RATIO OF .42 OR LESS
5,000 PSI MINIMUM CONCRETE @ 28 DAYS
VACUUM TESTING IS RANDOM BY CREST
TANKS DESIGNED TO WITHSTAND THE PRESSURES TO WHICH
IT WILL BE SUBJECTED PROVIDED INSTALLER TO FOLLOW
CREST BACK FILL AND BEDDING GUIDE #1-17
TANK SIZE MARKED ON OUTLET END

# APPLIED REFERENCE NO.

001, 002, 003, 004, 005, 07B, 008, 012 014, 017, 018, 019, 021, 022, 022A, 022B, 023 024 AND MOST RECENT APPROVALS THAT INCLUDE THE FOLLOWING OPTIONS: DOC APPROVED BEST, POLYLOCK OR ORENCO FILTERS SHALL BE LOCATED AS SHOWN AND WILL ALLOW FILTER REMOVAL PIPE PORTS; 4", 6", OR 8" RISER OPENINGS: MINIMUM 24" DIAMETER OPTION 35", 48", OR RECTANGLE / SQUARE WITH MINIMUM 24" CLEAR OPENING

## REINFORCEMENT

COVER: 1/2" REBAR 8" O.C.E.W. LOCATED 1 1/4" UP INSIDE FACE BOTTOM: 6 x 6 x 6 MESH LOCATED 1" FROM INSIDE FACE SIDES: 6 x 6 x 8 MESH LOCATED 1" FROM INSIDE FACE

### **MISC. NOTES**

JOINT SEALANT - HIGH GRADE EZ STICK OR CS101 LABELS - WARNING SIGNS LOCATED ON ALL MANHOLES INSTALLATION - SEE SEPARATE INSTALLATION GUIDE BAFFLES INSTALLED PIPE BOOTS ARE ALOK OR PRESS SEAL BRAND


### **EFFLUENT QUALITY**


WHEN THIS PRODUCT RECEIVES WASTEWATER FROM DWELLINGS AND IS USED AS A SEPTIC TANK, IT WILL PRODUCE AN EFFLUENT QUALITY WITH A MAXIMUM MONTHLY AVERAGE VALUE FOR BOD5 OF GREATER THAN 30MG/L AND LESS THAN OR EQUAL TO 220 MG/L ,TSS OF GREATER THAN 30MG/L OR LESS THAN OR EQUAL TO 150 MG/L TSS AND F.O.G. OF LESS THAN 30 MG/L.


# **SERVICE INTERVAL**


982 G.P.D. WHEN USED AS A SEPTIC TANK BASED ON A 3 YEAR SERVICE INTERVAL FOR RESIDENTIAL WASTE WATER.


47.7 G.P.I.













78"





Typical Cover Detail